



Management System
ISO 9001:2015
www.tuv.com
ID: 9108653506



OFFICE OF THE BAC CHAIRPERSON

December 20, 2020

ADDENDUM NO. 4

Series of 2020

CENTRALIZED POWER HOUSE (2MVA WITH PRIMARY AND SECONDARY LINES), CAMARINES NORTE STATE COLLEGE, MAIN CAMPUS, DAET, CAMARINES NORTE

This **Addendum No. 4 CENTRALIZED POWER HOUSE (2MVA WITH PRIMARY AND SECONDARY LINES), CAMARINES NORTE STATE COLLEGE, MAIN CAMPUS, DAET, CAMARINES NORTE** is being issued in accordance with the Revised IRR or R.A. 9184 specifically Section 22.5.2 & 22.5.3.

That this Addendum is being issued in view of the written query additional query raised by Kempal Construction and Supply Corporation on the following concerns and the corresponding response is as follows:

Query	Response of the BAC
1. For PCAB License Category since majority of the scope is Electrical Works may we request to allow PCAB Category is electrical with previous or reference project including civil works. The power house is for Electrical Equipment use. We have project reference with same scope that the power house or substation is included in the Electrical Package. Please confirm	For PCAB Category: Any contractor with PCAB License Classification of general engineering/general building with sub classification of electrical works, or with PCAB classification of electrical work with sub classification of general engineering/general building License category at least Medium B, size range at least A
2. For other item not included in the BOQ pay item. Do client allow us to inset other pay item included in the project but not stated in BOQ like project management and scope for supply and installation in First Private Pole.	The BAC resolved that bidders are not allowed to insert or alter any items in the Bill of Quantity(BOQ). Project Management Cost are included in the Overhead, Contingencies and Miscellaneous (OCM) which will not exceed to 8% of direct cost per work, must be reflected in the detailed estimate. If either plans, details, and scope of works includes the supply and installation of first private poles the bidders are required to indicate these items in the detailed estimates.
3. Please clarify the scope for Potential and Current Transformer. If this is intended for Primary Metering. This scope is for Local Utility or Service Provided.	This is the response of the preparer of the Program of Work that the potential and current transformer is included in the Contractor's Scope and subject for testing of the local utility. All items related to primary metering should be coordinated with the local electric cooperative (CANORECO) during implementation.

This Addendum shall form integral part of the Bid Documents.

Signed
LILIBETH A. ROXAS, Ph.D.
BAC CHAIRPERSON

